

## SOUTHERN CALIFORNIA GAS COMPANY PIPELINE/STATION MAINTENANCE SCHEDULE

### Receipt Capacity

Location Type	Location	Start Date	End Date	Maintenance Type	Description	Capacity Reduction (MMCF)	Capacity Reduction (Dth)
Area Zone	Needles/Topock Area Zone	07/01/2025	11/01/2026 11:59:59 PM PCT	Planned	L4000 and L4002 Operational Restrictions	405	415,044
Area Zone	Needles/Topock Area Zone	01/29/2025	05/09/2025 11:59:59 PM PCT	Unplanned	L235 West Necessary Remediation	540	553,392
Sub-Zone	EP-Ehrenberg/NBP-Blythe	05/01/2025	05/30/2025 11:59:59 PM PCT	Planned	L5000 and L2051 Remediation	650	668,264
Sub-Zone	TW-Topock/EP-Topock	10/01/2018	TBD	Planned	L3000 Operational Restrictions	190	194,693
Zone	CP-Line 85	05/15/2024	TBD	Unplanned	L8109 Maintenance	20	21,434
Zone	Northern Zone	07/01/2025	11/01/2026 11:59:59 PM PCT	Planned	L4000 and L4002 Operational Restrictions	655	673,929
Zone	Northern Zone	01/23/2025	05/09/2025 11:59:59 PM PCT	Unplanned	L235 West Necessary Remediation	175	180,057
Zone	Southern Zone	03/10/2018	TBD	Critical	Zone reduced because of seasonal load conditions	560	575,120

### Storage Injection Capacity

Location Type	Location	Start Date	End Date	Maintenance Type	Description	Capacity Reduction (MMCF)	Capacity Reduction (Dth)
Storage Field - Inj	Aliso Canyon	05/16/2025	TBD	Unplanned	Well Isolation. O&M. Reliability.	120	123,864
Storage Field - Inj	Aliso Canyon	05/16/2025	TBD	Unplanned	Well Limitations / Field Inventory	55	56,771
Storage Field - Inj	Aliso Canyon	05/16/2025	TBD	Planned	Storage Integrity Management Program (SIMP) Please Note: SIMP is continuous well inspection program. SoCalGas will post future SIMP related reductions as appropriate.	105	108,381
Storage Field - Inj	Aliso Canyon	04/29/2025	05/15/2025 11:59:59 PM PCT	Planned	Inventory Shut In	545	562,549
Storage Field - Inj	Aliso Canyon	04/26/2025	04/28/2025 11:59:59 PM PCT	Planned	Storage Integrity Management Program (SIMP) Please Note: SIMP is continuous well inspection program. SoCalGas will post future SIMP related reductions as appropriate.	105	108,381
Storage Field - Inj	Aliso Canyon	04/26/2025	04/28/2025 11:59:59 PM PCT	Unplanned	Well Limitations / Field Inventory	55	56,771
Storage Field - Inj	Aliso Canyon	04/26/2025	04/28/2025 11:59:59 PM PCT	Unplanned	Well Isolation. O&M. Reliability	120	123,864

Location Type	Location	Start Date	End Date	Maintenance Type	Description	Capacity Reduction (MMCF)	Capacity Reduction (Dth)
Storage Field - Inj	Aliso Canyon	04/21/2025	04/25/2025 11:59:59 PM PCT	Planned	Compressor / Main Unit Repair	545	562,549
Storage Field - Inj	Aliso Canyon	10/17/2024	04/20/2025 11:59:59 PM PCT	Planned	Storage Integrity Management Program (SIMP) Please Note: SIMP is a continuous well inspection program. SoCalGas will post future SIMP related reductions as appropriate.	105	108,381
Storage Field - Inj	Aliso Canyon	10/17/2024	04/20/2025 11:59:59 PM PCT	Unplanned	Well Isolation. O&M. Reliability	120	123,864
Storage Field - Inj	Aliso Canyon	10/17/2024	04/20/2025 11:59:59 PM PCT	Unplanned	Well Limitations / Field Inventory	55	56,771
Storage Field - Inj	Goleta	05/21/2024	08/31/2025 11:59:59 PM PCT	Unplanned	L1005 Maintenance	30	30,966
Storage Field - Inj	Goleta	05/21/2024	TBD	Unplanned	Mechanical limitations at Olive Street Compressor Station. Compression improvements discussed in the Test Year 2019 General Rate Case. Originally posted Feb 23, 2017.	20	20,644
Storage Field - Inj	Goleta	05/21/2024	TBD	Unplanned	Non Maintenance related due to diminished California Production. Not enough supply is available to meet North Coastal demand and injection.	50	51,610
Storage Field - Inj	Honor Rancho	03/26/2025	TBD	Unplanned	Main unit horsepower and RPM reductions are required due to mechanical limitations. Originally posted Feb 13, 2016	50	51,610
Storage Field - Inj	Playa del Rey	04/29/2025	TBD	Planned	Well Limitation / Field Inventory	50	51,610
Storage Field - Inj	Playa del Rey	04/27/2025	04/28/2025 11:59:59 PM PCT	Planned	Electrical Maintenance	75	77,415
Storage Field - Inj	Playa del Rey	03/10/2025	04/26/2025 11:59:59 PM PCT	Unplanned	Well Limitations / Field Inventory	50	51,610

### Storage Withdrawal Capacity

Location Type	Location	Start Date	End Date	Maintenance Type	Description	Capacity Reduction (MMCF)	Capacity Reduction (Dth)
Storage Field - Wth	Aliso Canyon	05/16/2025	TBD	Planned	Storage Integrity Management Program (SIMP). Please note: SIMP is a continuous well inspection program. SoCalGas will post future SIMP-related reductions as appropriate	660	681,252
Storage Field - Wth	Aliso Canyon	05/16/2025	TBD	Planned	Well Isolation. O&M. Reliability	135	139,347
Storage Field - Wth	Aliso Canyon	05/16/2025	TBD	Unplanned	Well Limitation / Field Inventory	255	263,211
Storage Field - Wth	Aliso Canyon	04/29/2025	05/15/2025 11:59:59 PM PCT	Planned	Inventory Shut In	1,850	1,909,570

Location Type	Location	Start Date	End Date	Maintenance Type	Description	Capacity Reduction (MMCF)	Capacity Reduction (Dth)
Storage Field - Wth	Aliso Canyon	01/22/2025	04/28/2025 11:59:59 PM PCT	Unplanned	Well Limitation / Field Inventory	255	263,211
Storage Field - Wth	Aliso Canyon	10/17/2024	04/28/2025 11:59:59 PM PCT	Planned	Well Isolation. O&M. Reliability	135	139,347
Storage Field - Wth	Aliso Canyon	10/17/2024	04/28/2025 11:59:59 PM PCT	Planned	Storage Integrity Management Program (SIMP). Please note: SIMP is a continuous well inspection program. SoCalGas will post future SIMP-related reductions as appropriate	660	681,252
Storage Field - Wth	Goleta	01/22/2025	TBD	Unplanned	Well Limitations / Field Inventory	20	20,644
Storage Field - Wth	Goleta	09/27/2024	TBD	Planned	Well Isolation. O&M. Reliability	50	51,610
Storage Field - Wth	Goleta	09/27/2024	TBD	Planned	Storage Integrity Management Program (SIMP). Please note: SIMP is a continuous well inspection program. SoCalGas will post future SIMP-related reductions as appropriate.	125	129,025
Storage Field - Wth	Goleta	05/21/2024	08/31/2025 11:59:59 PM PCT	Unplanned	L1005 Maintenance	30	30,966
Storage Field - Wth	Honor Rancho	03/26/2025	TBD	Unplanned	Well Isolation. O&M. Reliability	65	67,093
Storage Field - Wth	Honor Rancho	03/26/2025	TBD	Unplanned	Storage Integrity Management Program (SIMP) Please Note: SIMP is a continuous well inspection program. SoCalGas will post future SIMP-related reductions as appropriate.	185	190,957
Storage Field - Wth	Honor Rancho	03/26/2025	TBD	Unplanned	Well Limitations / Field Inventory	310	319,982
Storage Field - Wth	Playa del Rey	03/11/2025	TBD	Unplanned	Well Limitations / Field Inventory	10	10,322
Storage Field - Wth	Playa del Rey	03/11/2025	TBD	Unplanned	Storage Integrity Management Program (SIMP) Please note: SIMP is a continuous well inspection program. SoCalGas will post future SIMP-related reductions as appropriate.	125	129,025

Although SoCalGas has used reasonable efforts to assure its accuracy and timeliness, this information is preliminary operational data and can be negatively impacted by delays or errors in electronic transfers, data entry, communication failures, or other causes. No representation is made that the contents are free from error. SoCalGas assumes no responsibility for use of, or reliance on, this information by any party, and specifically advises such parties to discuss any decisions or actions related hereto with their own advisors and experts. Please also note that Storage field injection/withdrawal capacities are adjusted periodically depending on field pressures.

**Last updated: 04/18/2025 12:00 PM PCT**

Legend
<b>New</b>
<b>Revised Entry</b>
<b>Deleted</b>
<b>Completed/Expired</b>